

Declaration regarding the efficiency of a shower heat recovery unit


Kiwa Nederland B.V. hereby declares that of the shower heat recovery unit,

Type : Recoh – drain RD1-V1 (double separation wall)
Of : Hei-tech B.V.
In : Emmen, The Netherlands

of which a sample supplied and installed by Hei-tech B.V. has been tested according to the method described in NEN 5128 A1:2009, published 1 May 2009 and the correction letter of TNO 26 June 2009. The measurements have shown that the sample recovers the waste energy in the shower water with an efficiency of:

class	Flow (l/min)	Volume (l)	Efficiency (%)	Flow resistance (ΔP) (bar)
3	9.2	73	44.1	0.53
4, 5, 6	12.5	100	42.1	0.94

Apeldoorn, 7 September 2011



Ing. A.A. Slomp,
Product Manager,
Kiwa Nederland B.V.